

## Alarms Reported to Cambridge Fire Dept., 2006–07

Dorm	All Fire Alarms	Actual Fires <sup>a</sup>	Accidental Alarms	System Mal-functions	Malicious Alarms
East Campus, W. Parallel	12	5	4	1	2
Burton-Conner House	10	3	3	1	3
McCormick Hall	6	1	3	2	0
Simmons Hall	6	2	3	1	0
East Campus, E. Parallel	5	1	2	1	1
Baker House	4	2	1	0	1
MacGregor House	1	1	0	0	0

<sup>a</sup> Mostly cooking-equipment fires. Cooking fires resulted in 0 U.S. student deaths, 2002–05.

Sources: Cam. Fire Dept., Dispatchers' Logs; Natl. Fire Prot. Assn., *U.S. Structure Fires in Dormitories*, 2007.

The raw data for the table come from the City of Cambridge's public records, which are not copyright-protected.

Sept. 7, 2007